

# INTEGRATION OF RES AND H<sub>2</sub> STORAGE IN THE AZORES ARCHIPELAGO

Patrícia Rei José Pedro Fonseca Neven Duic Maria da Graça Carvalho




RE resources can be separated in two categories in terms of availability: those which are constant and continuous, possessing an intrinsic storage capacity, like hydro and geothermal, and those which are intermittent, lacking any such capacity. This last category is sub-divided into those resources varying periodically, like solar and tidal, and those that vary rather more randomly, such as wind and wave.



- The use of energy storage allows electricity generated during periods of high-availability/ low-demand to be converted (to a storable energy-form) and stored for subsequent resupply during periods of low availability or highdemand.
- In the absence of storage, the intermittent resource has to be matched by dedicated conventional capacity in order to guarantee supply.



# **Electricity production, storage and use**



NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002



- To look at ways to increase the penetration of Renewable Energy Sources in Corvo and Graciosa Islands
- To test the potentiality of the developed H2RES model devoted to this kind of work.
- To build and fully model scenaria for the Corvo and Graciosa islands to increase security of supply, and reduce pollution, based on existing load and meteorological data and envisaging the following technologies: wind, solar PV, and batteries and hydrogen storage.




### The target islands for the case studies



NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002



# **The Azores Electricity Balance**





### **Island of CORVO**

Year	<b>Consumption (</b> GWh)	<b>Production (</b> GWh <b>)</b>
2000	0.678	0.763
2001	0.723	0.809

#### **Island of GRACIOSA**

Year	<b>Consumption (GWh)</b>	<b>Production (GWh)</b>
2000	7.188	8.016
2001	7.684	8.573



The variation of the power output has an impact on both operation of the power system and on the power quality of the system and this impact increases as the level of penetration increases

Impact Change in renewable generation output	fluctuation >20% of peak	Mitigation options - Purchase additional controllable output
• Unpredictable instantaneous reduction in generation output	demand - Potential instantaneous loss >2% of peak demand	Purchase additional frequency control measures Purchase additional reserve
Unpredictable short-notice reduction output	Potential loss >3% of peak demand in an hour	services



- MG.1 An already planned enlargement by the local utility (EDA) of the wind park up to 530 kW with an imposed wind energy limit of 30% of the "instant" load in the system.
- MG.2 The same conditions as in MG.1 + 2,000 m<sup>2</sup> of installed PV.
- MG.3 30% RE contribution: wind power 1,200 kW, no restrains on the percentage of renewable energy with variable output placed into the grid.
- MG.4 45% RE contribution to the annual consumption: 1,200 kW of wind power + 20000 m<sup>2</sup> of PV, in the same conditions as in MG.3.
- MG.5 100% RE penetration: 9,000 kW of wind power + electrolyser with 8,900 kW power + 74 days hydrogen storage + fuel cell 1,600 kW power, allowing no renewable energy excess in the system.
- MG.6 100% RE penetration: 5,000 kW of wind power + 80,000 m<sup>2</sup> of PV + electrolyser with 8,500 kW power + 31 days hydrogen storage + fuel cell 1,750 kW power, allowing no renewable energy excess in the system.



- MC.1 60% re contribution to the annual consumption: 6,500 m<sup>2</sup> PV + 150 kW (18h) battery power, no restrains on the percentage of renewable energy with variable output placed into the grid.
- MC.2 80% re contribution: 10,000 m<sup>2</sup> PV + 150 kW (36h) battery power, in the same conditions as MC.1.
- MC.3 100% RE penetration: 25,000 m<sup>2</sup> PV + 170 kW (6 days) battery power
- MC.4 50% RE contribution: 200 kW of wind power, no restrains on the percentage of renewable energy with variable output placed into the grid.
- MC.5 30% RE contribution: 3,000 m<sup>2</sup> PV, in the same conditions as MC.4.




	MG. 1 (30% limit)	MG. 2 (MG.1 + 2000 M <sup>2</sup> PV)
Wind (kW)	530	530
Solar (kWp)	0	170
Renewable (kW)	530	700



	MG. 1 (30% limit)	MG. 2 (MG.1 + 2000 M <sup>2</sup> PV)
Wind output (GWh)	1.3	1.3
Solar output (GWh)	0	0.2
Ren. output (GWh)	1.3	1.5
Ren. taken (GWh)	1.1	1.2
Dump (GWh)	0.2	0.3


#### NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002





MG.1 simulation, January 1





MG.1 simulation, January 1. The source of electricity taken by the power system.



	MG. 3 MG. 4	
	(30% RE)	(MG. 3 + 45% RE)
Wind (kW)	1200	1200
Solar (kWp)	_	1700
Renewable (kW)	1200	2900
Wind output (GWh)	2.8	2.8
Solar output (GWh)	-	1.7
Ren. output (GWh)	2.8	4.5
Ren. taken (GWh)	2.7	4.0
Dump (GWh)	0.1	0.5

NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002




	MG. 5	MG. 6
	(100% RE)	(100% RE)
Wind (kW)	9000	5000
Solar (kWp)	-	6800
Renewable (kW)	9000	11800
Electrolyser (kW)	8900	8500
Storage vessel (GWh)	2.8	1.3
H2 storage (days)	74	31
Fuel cell (kW)	1600	1750



	MG. 5	MG. 6
	(100% RE)	(100% RE)
Wind output (GWh)	22.4	11.8
Solar output (GWh)	-	6.9
Ren. output (GWh)	22.4	18.7
Ren. taken (GWh)	5.8	6.3
Electrolyser (GWh)	16.6	12.4
Dump (GWh)	0	0
Fuel cell (GWh)	3.2	2.8
<b>Fuel cell serving time</b> (%)	45 %	40 %


#### NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002





MG.5 simulation, January 1, for this particular day more hydrogen is stored than retrieved






MG.5 simulation, hydrogen stored during the year



	MC.1	MC.2	MC.3
	(60% RE)	(80% RE)	(100% RE)
Solar (kW)	553	850	2125
Batteries (hours)	18	36	144
Batteries (kW)	150	150	170
Solar output (GWh)	562	864	2160
Ren. taken (GWh)	314	350	403
Excess (GWh)	248	514	1758
Stored (GWh)	245	411	560
Dump (GWh)	3	103	1198
Batteries serving time (%)	29	46	59


NEW AND RENEWABLE ENERGY TECHNOLOGIES FOR SUSTAINABLE DEVELOPMENT Ponta Delgada, Azores. 24 – 26 June 2002





MC.2 simulation, January 1






MC.2 simulation, January 1, the source of electricity taken by the power system.



	MC.4	MC.5
	(50% RE)	(30% RE)
Wind (kW)	200	-
Solar (kW)	-	255
Renewable (kW)	200	255
Wind output (GWh)	462	-
Solar output (GWh)	-	259
Ren. taken (GWh)	337	226
Dump (GWh)	125	33





MC.4 simulation, January 1, the source of electricity taken by the power system.



- The choice among the different scenaria depends mainly on comparing the costs of PV installation and of the hydrogen storage and on the available space.
- Due to actual high cost of PV, the scenaria involving only wind seems to be preferable.



### **CONCLUSIONS FOR CORVO ISLAND**

- For such a small energy system, 100% RE penetration with variable output, can only be reached by oversizing the power installed.
- This fact results in unacceptable values of energy excess. The possibility of using this energy excess to pump water for later energy generation in a mini-hydric power plant may be an option if the objective is 100% RE penetration.
- In order to reduce dumping, bigger batteries are needed.



- All options should be considered
- Wind + storage a possible way for 100% renewable Graciosa
- PV + storage a possible way for 100% renewable Corvo
- Intermittent RE + storage penetrations of up to 60% more viable - already significantly increasing security of supply and reducing pollution